

**CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN
ACCORDANCE WITH EN 13501-1:2007**

Sponsor	ISOBOOSTER BV Heliumstraat 5 NL-6422 PK HEERLEN The Netherlands
Prepared by	Efectis Nederland BV Lange Kleiweg 5 P.O. Box 1090 NL-2280 CB RIJSWIJK The Netherlands
Notified Body no.	1234

Efectis Nederland report | 2009-Efectis-R0778 | August 2009 |
ISOBOOSTER

4 / 5

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 11 of EN 13501-1:2007

4.2 Classification

The product, **ISOBOOSTER - insulation system covered with a 9.5 mm paper faced plasterboard**, in relation to its reaction to fire behaviour is classified:

B

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d0

Reaction to fire classification: B - s1, d0